

慈濟科技大學每人年平均用電資料

項目 年度	宿 舍 區		校 區		活動中心		美崙校區		全 區		樓地板面積 (使用執照) 全區(m²)	教職員 生總人 數	教職員生年 平均用電量 (度)全區	教職員生年 平均用電費 (元)全區	EUI 用電指標 (使用執照) 全區	EUI 用電指標 (使用執照) 宿舍	宿舍 住宿人數 均數	宿舍區 住宿人數 年平均用 電量(度)	表 8-5校地 校舍面積(m²) 校務基本資 料庫	EUI 用電指標 表8-5校務基 本資料庫
	用電量(度)	電費(元)	用電量(度)	電費(元)	用電量(度)	電費(元)	用電量(度)	電費(元)	總電量(度)	總電費(元)										
100年	2,033,500	6,291,847	2,272,800	\$7,372,192					4,306,300.0	\$13,664,039	102,879.41	2,624	1,641.12	\$5,207.33	41.86	44.13	1,581	1,286.21		
101年	2,030,700	\$5,908,767	2,207,300	\$7,359,126	9,262.30	\$27,911.80			4,247,262.3	\$13,295,805	107,046.79	2,634	1,612.48	\$5,047.76	39.68	44.07	1,710	1,187.54	109778	38.69
102年	1,940,070	\$6,142,358	2,191,274	\$7,701,354	34,430.80	\$98,988.68			4,165,774.8	\$13,942,701	107,046.79	2,615	1,593.03	\$5,331.82	38.92	42.11	1,730	1,121.43	109,779	37.95
103年	1,925,000	\$6,622,560	2,366,000	\$8,996,712	38,496.30	\$117,155.27			4,329,496.3	\$15,736,427	107,046.79	2,783	1,555.69	\$5,654.48	40.44	41.78	1,807	1,065.30	109,779	39.44
104年	1,972,100	\$6,394,081	2,459,000	\$8,774,761	36,100.70	\$103,192.53			4,467,200.7	\$15,272,035	107,046.79	2,879	1,551.65	\$5,304.63	41.73	42.80	1,955	1,008.75	109,779	40.69
105年	1,994,900	\$5,759,308	2,561,200	\$8,188,141	32,428.10	\$124,395.50			4,588,528.1	\$14,071,845	107,046.79	3,013	1,522.91	\$4,670.38	42.86	43.30	2,221	898.20	109,829	41.78
106年	2,168,500	\$6,314,202	2,543,600	\$8,069,035	34,068.10	\$86,311.66			4,746,168.1	\$14,469,549	107,096.98	3,170	1,497.21	\$4,564.53	44.32	47.06	2,615	829.25	107,097	44.32
107年	2,021,200	\$6,092,329	2,383,200	\$7,742,160	37,027.00	\$97,300.40			4,441,427.0	\$13,931,789	107,096.98	3,242	1,369.97	\$4,297.28	41.47	43.87	2,287	883.78	109,055	40.73
108年	2,074,700	\$6,273,919	2,329,300	\$7,635,794	34,126.50	\$83,943.20			4,438,126.5	\$13,993,656	107,096.98	3,286	1,350.62	\$4,258.57	41.44	45.03	2,389	868.44	111,801	39.70
109年	2,212,360	\$6,473,239	2,349,820	\$7,689,690	36,490.30	\$95,257.80			4,598,670.3	\$14,258,187	111,444.93	3,353	1,371.51	\$4,252.37	41.26	48.02	2,163	1,022.82	113,307	40.59
110年	2,264,084	\$6,484,482	2,387,980	\$7,625,105	29,293.70	\$75,790.90	24,512.70	\$94,246.42	4,705,870.4	\$14,279,624.3	113,517.66	3,383	1,391.03	\$4,220.99	41.45	49.14	1,994	1,135.45	115,328	40.80
111年	2,195,204	\$6,675,837	2,409,116	\$8,028,933	34,842.20	\$98,619.20	71,658.50	\$314,018.66	4,710,820.7	\$15,117,407.9	112,346.18	3,324	1,417.21	\$4,547.96	41.93	47.64	1,947	1,127.48	114,535	41.13
112年	1,926,216	\$7,537,907	2,344,984	\$7,720,158	35,303.70	\$108,570.50	34,897.30	\$142,074.67	4,341,401.0	\$15,508,710.2	112,291.68	3,141	1,382.17	\$4,937.51	38.66	41.81	2,094	919.87	114,318	37.98

機關學校用電指標(EUI)基準值

5-1大學 98.2

5-2科技大學 120.8

製表:113.01.10

ps:美崙校區用電資料提供至112年10月

EUI 校舍面積來自全國技專校院校務基本資料庫(保管組提供 表 8-5 校地校舍面積統計表,自101年起至今)